

TYPE TEST CERTIFICATE OF COMPLETE TYPE TEST

OBJECT	High-voltage cable system consisting of a 110 kV single-core power cable, two types of composite outdoor terminations, two GIS-terminations and one straight-through joint	
ТҮРЕ	composite outdoor termination 1: composite outdoor termination 2: GIS terminations:	A2XS(FL)2Y 1 x 800 (g) / 185-110 kV MKB 126 ESS145-C45 Connex gr. 5-S MCB 126
Rated voltage, U₀/	U (U _m) 64 / 110 (123) kV Conduc	ctor material AL
Conductor cross-s	ection 1 x 800 mm ² Insulati	ion material XLPE
MANUFACTURERS	See page 4	
CLIENT	Elsy Trading Limited, Balzers, Liechtenstein	
TESTED BY	KEMA HIGH-VOLTAGE LABORATORY Arnhem, the Netherlands	
DATE OF TESTS	6 October to 1 December 2011	

The object, constructed in accordance with the description, drawings and photographs incorporated in this Certificate, has been subjected to the series of proving tests in accordance with

IEC 60840 (2004)

This Type Test Certificate has been issued by KEMA following exclusively the STL Guides.

The results are shown in the record of Proving Tests and the oscillograms attached hereto. The values obtained and the general performance are considered to comply with the above Standard and to justify the ratings assigned by the manufacturer as listed on pages 4 to 12.

The Certificate applies only to the object tested. The responsibility for conformity of any object having the same designations with that tested rests with the Manufacturer.

This Certificate consists of 56 pages in total.

Version: 1

© Copyright: Only integral reproduction of this Certificate is permitted without written permission from KEMA. Electronic copies in e.g. PDF-format or scanned version of this Certificate may be available and have the status "for information only". The sealed and bound version of the Certificate is the only valid version.

KEMA Nederland B

S.A.M. Verhoeven Director Testing, Inspections And Certification The Netherlands

Arnhem, 15 May 2012