

INSPECTION REPORT

TIC 3240-13


OBJECT	Outdoor termination, type MKB 145 and a cross bonding joint, type MCB 145 X
	76/132 (145) kV
CLIENT	OMACS LLC, Moscow, Russia
MANUFACTURERS	Accessory 1 ARKASIL SK LLC, Moscow, Russia
	Accessory 2 ARKASIL SK LLC, Moscow, Russia
	Accessories See section 1.1.3 Characteristics of the accessories
INSPECTED BY	KEMA Nederland B.V., Arnhem, The Netherlands
TEST LOCATION	OMACS LLC, Moscow, Russia
DATE(S) OF TESTS	4 July to 23 September 2013
TEST SPECIFICATION	The tests have been carried out based on IEC 60840 (2011), clause 15.4.
SUMMARY AND CONCLUSION	The outdoor termination and the cross bonding joint passed the tests.

This report applies only to the object tested. The responsibility for conformity of any object having the same type references as that tested rests with the manufacturer.

This report consists of 45 pages in total.

Copyright: Only integral reproduction of this report is permitted without written permission from KEMA. Electronic copies in e.g. PDF-format or scanned version of this report may be available and have the status "for information only". The sealed and bound version of the report is the only valid version.

KEMA Nederland B.V.

A blue ink signature, appearing to read "S.A.M. Verhoeven", is written over the printed name and title.

S.A.M. Verhoeven
Director Testing, Inspections &
Certification The Netherlands

Arnhem, 4 March 2014