

INSPECTION REPORT

3072-15

OBJECT	Outdoor termination and GIS termination
	MKB 252 P MBB 252
CLIENT	Omacs L.L.C., Moscow, Russia
MANUFACTURERS	Accessories Arkasil S.K., Moscow, Russia Cable Estralin HVC L.L.C., Moscow, Russia
INSPECTED BY	KEMA Nederland B.V., Arnhem, The Netherlands
TEST LOCATION	Arkasil S.K., Moscow, Russia
DATE OF TESTS	3 November 2014 to 25 February 2015
TEST SPECIFICATION	The tests have been carried out based on IEC 62067 (2001), clause 12.4.
SUMMARY AND CONCLUSION	This type test concerns the accessories only, the cable was not a test object. The porcelain outdoor termination and the GIS termination both passed the tests.

This report applies only to the object tested. The responsibility for conformity of any object having the same type references as that tested rests with the manufacturer.

This report consists of 35 pages in total.

Copyright: Only integral reproduction of this report is permitted without written permission from KEMA. Electronic copies in e.g. PDF-format or scanned version of this report may be available and have the status "for information only". The sealed and bound version of the report is the only valid version.

KEMA Nederland B.V.

A blue ink signature, appearing to read "S.A.M. Verhoeven", is written over the printed name and title.

S.A.M. Verhoeven
Director Testing, Inspections &
Certification The Netherlands

Arnhem, 1 May 2015