

MBB A 126 – Cu 1000 / 185 T M O H E

Types of GIS cable terminations:
T–transformer cable termination
M–welding connection between conductor and termination connector
B–screwed cable connector
O– GIS cable termination has optical fiber output
H–termination for armored cable
E–extension adapter (IEC 62271–209 Fig.3)

35...400– Cu screen cross–section
(Al 35...400 – Al screen cross–section
Pb – Lead sheath)

M – Solid rod conductor

185...2500 – Conductor cross–section

Cu, Al – Conductor material

126, 145, 170, 252 – Maximum system voltage

Put in case of separate delivery:

P –epoxy insulator set / C – plug–in set

Size of epoxy insulator A/B (126–170 kV only)

MBB – GIS cable termination